Through Eave Meter Base Installation

Yazoo Valley EPA "Strong on Service"

\$75.00 REINSPECTION **FEE IF METER BASE IS NOT INSTALLED AS SHOWN**

Note: Meter Base Shall Have A Min. Clearance of 3' from Windows, Doors, and Gas Meter.

Weather Head Shall Extend-36" Through Roof Service Wire 18" Min. Req'd.-Galvanized Pipe Reg'd: (Thin Wall Conduit Is Not Acceptable) Meter E Ground Line Ground Wire in 1/2" Conduit 5" x 8' Copper Ground Rod

Customer Wiring Size

				•	
*************COPPER********					
Meter	Conduit	Conductor	Neutral	Ground	Equipment
Size	Size	Wire	Wire	Wire	Ground Wire Size
		Size	Size	Size	(Fourth Wire)
60 amp	1"	#4	#4	#6 Copper	#6 Copper Insulated
100 amp	2"	#2	#4	#6 Copper	#6 Copper Insulated
200 amp		#2/0	#1/0	#4 Copper	#6 Copper
********ALUMINUM******					
Meter	Conduit	Conductor	Neutral	Ground	Equipment
Size	Size	Wire	Wire	Wire	Ground Wire Size
		Size	Size	Size	(Fourth Wire)
60 amp	1"	#2	#4	#6 Copper	#6 Copper Insulated
100 amp	2"	#1/0	#2	#6 Copper	#6 Copper Insulated
200 amp	2"	#4/0	#2/0	#4 Copper	#6 Copper Insulated

Yazoo Valley EPA Through Eave & Side Of House Meter Base Installation Date: 5/9/2016

Checked by: MN Scale: None Drawn by: MN Revised by: RB Date: 7/27/2023

Approved by: MN

Main Meter Combo Load Center Or Meter Base With Separate Emergency Disconnect Meeting 2020 NEC Code 230.85

> Note: 4 Wire Service From Outside Disconnect to Inside House

Side Of House Meter Base Installation

